

ADDENDUM 2
DEVONSHIRE APARTMENTS
WESCOTT ROAD, COLUSA, CA 95932

1. Can a TPO roofing system be used in place of the foam and elastomeric roofing.
A TPO or EPDM roofing system is acceptable if they meet or exceed the warranty of the specified roofing product.