

ADDENDUM 2
LANDING, STAIR & SIDING REPAIRS
RICHLAND MIGRANT CENTER
479 BERNARD AVE.
YUBA CITY, CA 95991

1. Are there any new footings being installed, there is a detail but no notes on the plans?

No, all footings are existing.

2. Can you verify that there are no new stair treads, that we are only modifying the existing?

There are no stair treads scheduled to be replaced. Existing treads will need to have the contrasting color on the front edge and the risers between treads filled.