

ADDENDUM 4

Julia Vierstra

15124 Jack Pine Way, Magalia, CA 95954

1. PEX is only getting changed under the modular and not in the walls also correct?

All of the existing vinyl hot and cold water lines are to be changed, including any in the walls.